

# Confirmation

Soudal N.V. confirms that the foam sealant with the name :

## Flexifoam

Shows low VOC contents as specified in LEED credit EQ 4.1 ( Adhesives and Sealants ).

VOC contents is below the limit value specified by weight of foam sealant.

Sample identification	<b>Flexifoam</b>
Product type	Foam sealant
Product data, according to Soudal NV	No exempt compounds present No water present Density 1,00 g/ml

	Water content, %mass	VOC less water less exempt compounds g/l	VOC limit g/l
<b>Flexifoam</b>	0	160	200

With this confirmation, use of product Flexifoam may qualify for fulfillment of LEED credit EQ 4.1 ( Adhesives and Sealants ).

01 January 2019



Luc Thys  
Director Marketing and R&D



Jonas Daelemans  
Technical Product Manager

*Use of US Green Building Council Member logo does not imply that USGBC has approved this confirmation or any mentioned product.*